

LA-UR-17-30411

Approved for public release; distribution is unlimited.

Title: Lujan Mark-4

Author(s): Mocko, Michael Jeffrey

Zavorka, Lukas Koehler, Paul E.

Intended for: Mark-IV Target Neutronics Design Review

Issued: 2017-11-13



Lujan Mark-4

Physics design proposal



M. Mocko, L. Zavorka, P. Koehler

Nov 15, 2017




Lujan TMRS: historical perspective


- Mark-0: first attempt (1995-1998)
- Mark-I: rather short lifetime (1998-2001)
 - Lead reflector cooling failure
- Mark-II: minor changes from Mark-I (2002-2010)
 - Lead reflector replaced by beryllium
 - Degradation of performance in last two years of operation
- Mark-III: (2010-today)
 - Ta-clad tungsten targets
 - Cold Be reflector-filter
 - Other small optimizations (MACOR, pre-moderators)
- Mark-IV: planned for installation during 2020 outage
 - Major redesign of the upper tier, offering harder neutron spectra for upper-tier FPs
 - Redesign of the high-resolution (HR) moderator
 - Preserve the rest of Mark-III features (Ta-clad tungsten targets, cold be reflectorfilter)

Lujan TMRS Mark-III: facts


- TMRS assembly——
 - 3 meters tall
 - 60 cm in diameter
- Split tungsten target
 - Ta-clad, water cooled
- Vertical proton beam delivery
- 16 neutron flight paths in two horizontal planes
- Upper tier:
 - 2 FPs water moderator
 - 2 FPs liquid hydrogen moderator
- Lower tier:
 - 9 FPs three water moderators
 - 3 FPs liquid hydrogen moderator coupled with beryllium reflector-filter



Lujan TMRS: detailed MCNP model




Validation: cold neutron spectra



M. Dubey, M. S. Jablin, P. Wang, M. Mocko, J. Majewski; Eur. Phys. J. Plus 126 (2011) p110

Validation: time emission spectra



FP-5 time emission spectra (Mark-II)

2 meV

8 meV

26 meV

66 meV

100

Time (µs)


Time (µs)

Time (µs)

Time (µs)

M. Mocko et al., NIMA 632 (2011) 101-108


Mark-III: FP-9




M. Mocko and G. Muhrer, NIMA 704 (2013) 27-35

Validation: response function FP-14 simulations

- Better understand the resolution and energy calibration
- Detailed simulations with real proton pulse distribution for FP-14
- Time emission spectra 1 eV 1 keV
- Experimental data for ²³⁸U(n,g)²³⁹U






Data ENDF ENDF⊗SIM

Lujan TMRS Mark-IV design philosophy

- Growth areas emerging in nuclear science fields
- Fundamental challenges
 - 1. TMRS is optimized for superior thermal and cold neutronic performance (material science)
 - 2. Emerging applications need more medium energy neutrons (nuclear physics)
- How do we retain (1) and enable new experiments (2) at the same time?



GOOD: Two-tiered design naturally lends itself to serve two very different customer bases.

BAD: We are not producing more neutrons overall!


Lujan Mark-IV: proposed design changes

Lower tier:

- Redesigning the High-Resolution moderator, offers more flexibility (two modes of operation)
- Optimizing the middle target thickness and position

• Upper tier:

- Complete redesign main components:
 - Moving the upper target into the field of view
 - Removing beryllium reflector
 - · Water liner for outer lead reflector
 - Water liner separating the lower from upper tier neutronically
- Compact target with moderator wings



Lower tier design changes

High-resolution moderator redesign

- Thinner pre-moderator
- Additional volume that could be filled with water upon demand
- Changes enable two modes of operation: high resolution and high intensity
- High-resolution mode
 - Small increase (6%) in thermal neutron intensity over Mark-III
- High-intensity mode
 - 60% increase in thermal neutron intensity over Mark-III
 - Resolution worsening by about 10%


Rest of lower-tier moderators intact

- Two water high-intensity moderators
- Partially-coupled liquid hydrogen moderator with Be reflector-filter

Middle target


Taller (thicker) middle target yields slightly higher neutron output for lower tier


High resolution moderator redesign



Moderator-2 filled with water: HI-mode Moderator-2 filled with helium: HR-mode

HR moderator performance





Ratio at maximum flux:

HI Mode	HR Mode
1.84	1.06


Total gain in thermal flux:

HI Mode	HR Mode
57%	6.1%

Increase in background $(E_n > 0.5 \text{ eV})$:

HI Mode	HR Mode
-0.3%	13.7%

HR moderator performance



Change in resolution: (backscattering)

Energy (meV)	HI Mode (us)	HR Mode (us)
13.4	+7.0	-0.4
60.4	+6.3	1.2
111.0	+1.0	0.2


Change in resolution: (backscattering)

Energy (meV)	HI Mode	HR Mode
13.4	+17.1%	-0.9%
60.4	+27.9%	+5.5%
111.0	+4.6%	+1.1%


Upper-tier design


- Improving performance in keV region (1 eV to 100 keV)
- Increasing neutron flux:
 - Undermoderated system
 - Production region in line of sight of neutron FPs
- Improving resolution:
 - eliminating reflector material
 - small neutron production region
- Resulting design
 - Removing beryllium reflector and upper-tier moderators
 - Compact spallation target
 - Small moderator covering the field-of-view
 - Water layers neutronically separating the outer reflectors, lower tier from the uppertier flight paths

Minimizing reflector influence




Compact target-moderator assembly







Upper tier field of view discussion



- FOV Real: Existing upper-tier flight paths
- FOV Center: Requires flight path reconfiguration

Optimization studies









2.4 2.0 2.0 10⁰ 10¹ 10² 10³ 10⁴ 10⁵ Energy (eV)


Disk versus Rod geometry

 $L_{\rm m}$ is flight path length uncertainty calculated from FWHM of time emission spectra

Measure of background: gamma emission








Prompt emission = gamma flash (<1 μ s) Delayed emission = everything else (after 1 μ s)

Upper tier design: conclusions





$$FOM(E) = \frac{\phi(E)}{FWHM^2(E)}$$

Design	FOV	FOM ratio	g-ray background ratio (prompt : delayed)	M4/M3 lower-tier flux (%)
Disk	Center	4	9:2	72
	Real	2	2:2	72
Rod	Center	2	6:2	74
	Real	1	1:1	74

Backup slides

Validation: thermal neutron spectra





Excellent reproduction of experimental data. Difference between Exp. 2009 and Exp. 2010 corresponds to end-of-life Mark-II versus Mark-III, demonstrating degradation of performance.

Excellent reproduction of experimental data when simulating the experimental setup. The results obtained with point detector overestimate the experimental data due to uncertainty in beam spot area determination.